



REQUEST FOR PROPOSAL
February 17, 2021

The City of Tehachapi is requesting proposals for Water Storage Tank Cleaning and Inspections. These inspections occur every three years and we intend for the work to be done between September 2021 and November 2021.

The City of Tehachapi is soliciting proposals from professional tank maintenance service providers with substantial experience in the inspection, renovation, painting, and preventive maintenance of potable water storage facilities. The contract will include, but is not be limited to, preventative maintenance associated with water storage tanks, inspection services, rehabilitation and repair, repainting, washout, disinfection, and preventative maintenance of the City of Tehachapi's five welded steel storage tanks.

Proposals are to be delivered and titled or marked: "**2021 Tank Cleaning & Inspections**", by 5:00pm on March 17th, 2021.

The address for hand delivery or Mail delivery is listed below:

City of Tehachapi
115 South Robinson Street
Tehachapi, CA 93561

The email address for electronic delivery is listed below:

tnapier@tehachapipw.com

Proposals received after the specified date and time will not be considered. The City of Tehachapi reserves the right to accept or reject any or all proposals, to waive formalities and technicalities, and to make an award in the best interest of the City of Tehachapi.

Factors to be considered in making this award, if awarded, will be equipment, price, warranty, and references. The City of Tehachapi will be the sole judge of the weights given these factors.

Prices quoted shall be firm prices and remain firm until the work is done. If awarded, the City of Tehachapi will provide a purchase order with the successful bidder within 14 days after the proposals are due.

Prevailing Wage:

- Price must be bid based upon the current Prevailing Wage Rates for Kern County.

Interpretations:

- In order to be fair to all proposers, no verbal interpretations will be given to any proposer, as to the meaning of any of the requested specifications. Every request for such a consideration shall be made in writing.

Please contact Tyler Napier, Deputy Public Works Director at 661-822-2200 Extension 507 should you have any questions.

Proposal Format:

- Proposals shall include a breakdown of services to be provided based upon the scope of work listed below. Proposals shall be broken down to be a lump sum cost for all five tanks.

City of Tehachapi
Specifications for Tank Cleaning and Inspections

Various Items requested:

- Provide three (3) professional references with for similar work completed within the past year.
- Provide a detailed/itemized list of all options that are available that are not requested in this document.

Scope of Work (All Tanks):

- Remove up to three (3) inches of sediment from tank floor
- Visual Inspection of the interior and exterior of the tank
- Provide a written and electronic report including:
 - Still photos of findings
 - Recommendation for repairs
 - Condition (written & Photos) of all internal and external appurtenances
- Provide DVD of the dive (one per tank)

Tank Specifications:

Tank Name		Tank Diameter	Typical Water Depth	Tank Size	Tank Construction	Internal Ladder Access
Curry Tank (NW)	Same Location	90'	26'	1.1 MG	Welded Steel	Yes
Curry Tank (NE)		90'	26'	1.1 MG	Welded Steel	Yes
Curry Tank (SW)		66'	26'	.75 MG	Welded Steel	Yes
Curry Tank (SE)		66'	26'	.75 MG	Welded Steel	Yes
Highline Tank		112'	24'	1.5 MG	Welded Steel	Yes